



Report No: - C & I/ 250096

Date: -22.03.2025

TEST REPORT

Name of Customer	Apex International School NH-27, Near Police Lines Road, Baran-Kota Highway, Baran-325205
Reference No.	Letter Date: - 21.03.2025
Lab. Job No.	250096
Sample Receipt Date	21.03.2025
Name of Work	-----
Material/ Material Identification	Water Sample
Make/Source	-----
Date of Testing	22.03.2025

Discipline: Chemical Testing

Group: Water


TEST RESULTS

S.No.	Parameters	Results	Test Method	Requirement (Acceptable Limit) as per IS10500-2012 RA 2018 Max.
1.	pH Value	6.98	IS-3025-P(11):1983	6.5-8.5
2.	Turbidity (NTU)	Nil	IS-3025-P(10):1982	1.0
3.	Taste	Agreeable	IS-3025-P(8):1984	Agreeable
4.	Colour	APHA	IS-3025-P(4):1987	5
5.	Odour	Agreeable	IS-3025-P(5):1983	Agreeable
6.	T.D.S. (ppm)	130	IS-3025-P(16):1984	500
7.	Total Hardness (mg/lit.)	110	IS-3025-P(21):2009	200
8.	Acidity (mg/lit.)	Nil	IS-3025-P(22):1986	---
9.	Alkalinity (mg/lit.)	80	IS-3025-P(23):1986	200
10.	Chloride (mg/lit.)	36.5	IS-3025-P(32):1988	250
11.	Sulphate (mg/lit.)	24	IS-3025-P(24):1986	200
12.	Calcium (mg/lit.)	24	IS-3025-P(40):1991	75
13.	Magnesium (mg/lit.)	12.2	IS-3025-P(46):1994	30
14.	Fluoride (as F) mg/l	0.32	IS 3025 (Part 60):1994	1.0

Checked by: *Sunanda*

Note: -

1. The test result refers only to the samples received in the Laboratory.
2. This report shall not be reproduced except in full without written approval from C&I SYSTEMS Laboratory.
3. Any discrepancy in test results should be reported within 15 days from the date of report.
4. C&I SYSTEMS Laboratory shall not in any way be involved in any action following the interpretation of test results.
5. This report is not valid for any Legal proceeding.



Authorized Signatory: *Sunanda*

End of Report